

Loss Prevention Certification Board



This is to certify

Geberit Mapress GmbH
40764 Langenfeld, Germany

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

**Geberit Mapress Press-Fit Lightweight Galvanised and Stainless Steel
Sprinkler Pipework Systems**
(refer to attached appendix for details)

which have complied with the requirements of the following:

TS1599: Issue draft 5

Certificate No. 1031a & 1031b Issue No. 01

Date of Issue 14th April 2011

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB



P J Field

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 1031

Geberit Mapress GmbH

Certificate No: 1031a to TS1599 v5

Geberit Mapress Press-Fit Lightweight Galvanized Steel Sprinkler Pipework System

Description	Size/mm	LPCB Ref
Pipe	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/01
Coupling	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/02
Slip Coupling	22, 28, 35, 42, 54, 76.1, 88.9, 108	1030a/03
Bend 90°	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/04
Bend 90° with plain end	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/05
Bend 45°	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/06
Bend 45° with plain end	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/07
Reducer with plain end	28x22, 35x22, 35x28, 42x28, 42x35,	1031a/08
	54x35, 54x42, 76.1x54, 88.9x54	
	88.9x76.1, 108x76.1, 108x88.9	
T-piece equal	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031a/09
T-piece reduced	28x22x28, 35x22x35, 35x28x35, 42x22x42	1031a/10
	42x28x42, 42x35x42, 54x22x54, 54x28x54	
	54x35x54, 54x42x54, 76.1x22x76.1, 76.1x28x76.1	
	76.1x35x76.1, 76.1x42x76.1, 76.1x54x76.1, 88.9x22x88.9	
	88.9x28x88.9, 88.9x35x88.9, 88.9x42x88.9, 88.9x54x88.9	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

P J Field


Page 2 of 7

Date of Issue 14th April 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 1031

Geberit Mapress GmbH

Description	Size/mm	LPCB Ref
T-piece reduced (Cont)	88.9x76.1x88.9, 108x22x108, 108x28x108, 108x35x108	1031a/10
	108x42x108, 108x54x108, 108x76.1x108, 108x88.9x108	
T-piece with female thread	22x1/2"x22, 22x3/4"x22, 28x1/2"x28, 28x3/4"x28,	1031a/11
	28x1"x28, 35x1/2"x35, 35x3/4"x35, 42x1/2"x42	
	42x3/4"x42, 54x1/2"x54, 54x3/4"x54, 54x2"x54	
	76.1x3/4"x76.1, 76.1x2"x76.1, 88.9x3/4"x88.9, 88.9x2"x88.9	
	108x3/4"x108, 108x2"x108	
Adaptor with male thread	22x1/2", 22x3/4", 22x1", 28x3/4", 28x1", 28x1 1/4",	1031a/12
	35x1", 35x1 1/4", 35x1 1/2", 42x 1 1/4", 42x1 1/2"	
	54x1 1/2", 54x2", 76.1x2 1/2", 88.9x3"	
Adaptor with female thread	22x3/4", 28x1/2", 28x1"	1031a/13
Adaptor with plain and welding end	15, 18, 22, 28, 35, 42, 54	1031a/14
Adaptor for groove systems	54	1031a/15
Adaptor with brass union nut	22x1", 22x 1 1/4", 22x 1 1/2", 28x1", 28x1 1/4"	1031a/16
	28x1 1/2", 35x1 1/2", 35x2", 42x1 3/4", 42x2", 42x 2 1/4",	
	42x 2 3/8", 42x 2 1/2", 54x 2 1/2", 54x 2 3/4"	
Adaptor union with male thread	22x3/4", 28x1", 35x1 1/4", 42x1 1/2", 54x2"	1031a/17
Adaptor union with female thread, nut made of stainless steel	22x3/4", 22x1", 28x1", 35x1 1/4", 42x1 1/2", 54x2"	1031a/18

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

P J Field


Page 3 of 7

Date of Issue 14th April 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 1031

Geberit Mapress GmbH

Description	Size/mm	LPCB Ref
Elbow adaptor 90° with male thread	22x3/4"	1031a/19
Elbow adaptor 90° with female thread	28x1/2"	1031a/20
Bend adaptor 90° with female thread	22x3/4", 28x1/2"	1031a/21
Straight union with press fittings on both ends	22, 28, 35, 42, 54	1031a/22
Flange PN 10 / 16 with pressing socket	76.1, 88.9, 108	1031a/23
Cap	22, 28, 35, 42, 54	1031a/24

Certificate No: 1031b to TS1599 v5

Geberit Mapress Press-Fit Lightweight Stainless Steel Sprinkler Pipework System

Description	Size/mm	LPCB Ref
Pipe	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/01
Coupling	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/02
Slip Coupling	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/03
Bend 90°	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/04
Bend 90° with plain end	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/05
Bend 45°	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/06

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

P J Field

Page 4 of 7

Date of Issue 14th April 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 1031

Geberit Mapress GmbH

Description	Size/mm	LPCB Ref
Bend 45° with plain end	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/07
Reducer with plain end	28x22, 35x22, 35x28, 42x28, 42x35,	1031b/08
	54x35, 54x42, 76.1x54, 88.9x54	
	88.9x76.1, 108x76.1, 108x88.9	
T-piece equal	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/09
T-piece reduced	28x22x28, 35x22x35, 35x28x35, 42x22x42	1031b/10
	42x28x42, 42x35x42, 54x22x54, 54x28x54	
	54x35x54, 54x42x54, 76.1x22x76.1, 76.1x28x76.1	
	76.1x35x76.1, 76.1x42x76.1, 76.1x54x76.1, 88.9x22x88.9	
	88.9x28x88.9, 88.9x35x88.9, 88.9x42x88.9, 88.9x54x88.9	
	88.9x76.1x88.9, 108x22x108, 108x28x108, 108x35x108	
	108x42x108, 108x54x108, 108x76.1x108, 108x88.9x108	
T-piece with female thread	22x1/2"x22, 22x3/4"x22, 28x1/2"x28, 28x3/4"x28,	1031b/11
	28x1"x28, 35x1/2"x35, 35x3/4"x35, 42x1/2"x42	
	42x3/4"x42, 54x1/2"x54, 54x3/4"x54, 54x2"x54	
	76.1x3/4"x76.1, 76.1x2"x76.1, 88.9x3/4"x88.9, 88.9x2"x88.9	
	108x3/4"x108, 108x2"x108	
Adaptor with male thread	22x1/2", 22x3/4", 22x1", 28x3/4", 28x1", 28x1 1/4",	1031b/12
	35x1", 35x1 1/4", 35x1 1/2", 42x 1 1/4", 42x1 1/2"	

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

P J Field

Page 5 of 7

Date of Issue 14th April 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 1031

Geberit Mapress GmbH

Description	Size/mm	LPCB Ref
Adaptor with male thread (Cont)	54x1 1/2", 54x2", 76.1x2 1/2", 88.9x3"	1031b/12
Adaptor with female thread	22x1/2", 22x3/4", 22x1", 28x1/2", 28x3/4", 28x1"	1031b/13
	28x1 1/4", 35x1"	
	35x1 1/4", 35x1 1/2", 42x 1 1/4", 42x1 1/2"	
	54x1 1/2", 54x2"	
Adaptor with brass union nut	22x1", 22x 1 1/4", 22x 1 1/2", 28x1", 28x1 1/4"	1031b/14
	28x1 1/2", 35x1 1/2", 42x1 3/4", 54x2 3/8", 76.1x3", 88.9x3 1/2"	
Adaptor with stainless steel union nut	22x1", 28x1 1/2"	1031b/15
Adaptor union with male thread, nut made of stainless steel	22x1/2", 22x3/4", 22x1", 28x1/2", 28x3/4", 28x1"	1031b/16
	35x1 1/4", 42x1 1/2", 54x2"	
Adaptor union with male thread, nut made of brass	22x1/2", 22x3/4", 22x1", 28x1", 35x1 1/4", 42x1 1/2", 54x2"	1031b/17
Adaptor union with female thread, nut made of brass	22x3/4", 22x1", 28x1", 35x1 1/4", 42x 1 1/2", 54x2"	1031b/18
Adaptor union with female thread, nut made of stainless steel	22x3/4", 22x1", 28x1", 35x1 1/4", 42x1 1/2", 54x2"	1031b/19
Elbow adaptor 90° with male thread	22x3/4", 28x1", 35x1 1/4", 42x1 1/2", 54x2"	1031b/20
Elbow adaptor 90° with female thread	22x3/4", 28x1", 35x1 1/4"	1031b/21
Straight union with press fittings on both ends	22, 28, 35, 42, 54	1031b/22
Flange PN 10 / 16 with pressing socket	22, 28, 35, 42, 54, 76.1, 88.9, 108	1031b/23
Cap	22, 28, 35, 42, 54	1031b/24

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

P J Field

Page 6 of 7

Date of Issue 14th April 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 1031

Geberit Mapress GmbH

Notes

1. The above Geberit Mapress Press-fit pipework and fittings are to be installed using the Geberit Mapress ECO301 and HCPS pressing tools only, in accordance with the Geberit Installation Instructions. These tools shall be serviced and maintained in accordance with manufacturers' stated guidelines.
2. Geberit Mapress Press-fit pipework and fittings may only be installed by LPCB Approved sprinkler Contractors who have undergone adequate training by the manufacturer.
3. Geberit Mapress Press-fit pipework and fittings shall be installed in accordance with the Geberit Installation Instructions, Issue 1. May 2011.
4. Geberit Mapress Press-fit pipework and fittings shall be installed and maintained in conformance with the LPC Rules for Automatic Sprinkler Installations.
5. The use of Geberit Mapress Press-fit pipework and fittings shall be recorded on LPS1048 certificates of conformity.
6. Where a Geberit Mapress Reducer is installed, a pipe hanger shall be used adjacent to the reducer on the larger pipe.
7. Where Geberit Mapress system pipework is connected to sprinklers in suspended ceilings using flexible drops, only LPCB Approved flexible drops shall be used.
8. Geberit Mapress Press-fit pipework and fittings are not compatible with lightweight piping systems from other manufacturers.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

P J Field

Page 7 of 7

Date of Issue 14th April 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.